

KC/KDHC/K15/K17

Labor shall be based on the following:

Construction

- Assemble in accordance to Construction Specification Drawing and Specifications for Construction

Removal

- Remove neutral messenger conductor from clamp and removal specified unit
- All Removed Material shall be returned to the District Storeroom in which the project is located

Replacement

- Remove neutral messenger conductor from clamp and Remove the Specified Unit including any associated labor and temporary material required for safe removal of Existing Specified Unit (i.e. conductor support, etc)
- Installation of New Specified Unit and install neutral messenger conductor into the clamp in accordance to specification drawing and specification for construction and any associated labor for removal of temporary material (i.e. conductor support, etc.)
- All Removed Material shall be returned to the District Storeroom in which the project is located

K10

Labor shall be based on the following:

Construction

- Assemble in accordance to the Construction Specification Drawing and Specifications for Construction

Removal

- Remove the neutral messenger conductor from clamp and remove the specified unit
- All Removed Material shall be returned to the District Storeroom in which the project is located

Replacement

- Remove the neutral messenger conductor and then Remove the Specified Unit including any associated labor and temporary material required for safe removal of Existing Specified Unit (i.e. conductor support, etc)
- Installation of New Specified Unit and the neutral messenger conductor in accordance to the Construction Specification Drawing and Specifications for Construction and associated labor for removal of temporary material (i.e. conductor support, etc.)
- All Removed Material shall be returned to the District Storeroom in which the project is located

K11/K14

Labor shall be based on the following:

Construction

- Assemble in accordance to Construction Specification Drawing and Specifications for Construction

Removal

- Remove the neutral messenger conductor from clamp and remove the specified unit
- All Removed Material shall be returned to the District Storeroom in which the project is located

Replacement

- Remove the neutral messenger conductor and then Remove the Specified Unit including any associated labor and temporary material required for safe removal of Existing Specified Unit (i.e. conductor support, etc)
- Installation of New Specified Unit and reinstall the neutral messenger conductor in accordance to the Construction Specification Drawing and Specifications for Construction and associated labor for removal of temporary material (i.e. conductor support, etc.)
- All Removed Material shall be returned to the District Storeroom in which the project is located

K18/K19

Labor shall be based on the following:

Construction

- Assemble in accordance to Construction Specification Drawing and Specifications for Construction

Removal

- Remove the neutral messenger conductor from clamp and removal specified unit
- All Removed Material shall be returned to the District Storeroom in which the project is located

Replacement

- Remove the neutral messenger conductor from clamp and then Remove Specified Unit including any associated labor and temporary material required for safe removal of Existing Specified Unit (i.e. conductor support, etc)
- Installation of New Specified Unit and reinstall the neutral messenger conductor into clamp in accordance to the Construction Specification Drawing and Specifications for Construction and any associated labor for removal of temporary material (i.e. conductor support, etc.)
- All Removed Material shall be returned to the District Storeroom in which the project is located